

SOUND & VIBRATION CONTROL

Acceptable vibration for all rotating equipment shall be no greater than shown in the 1991 ASHRAE HVAC Applications Handbook, Chapter 42 (Sound and Vibration Control), Figure 43 using the .1 in/sec fair (IRD) curve.

01/26/00 04:34 PM